



Certified Water Testing

VELAP ID: 460012

VA DW ID: 00240

EPA ID: VA00050

1851 Rippon Boulevard

Woodbridge, VA 22191

703-393-2071

Average Point of Entry Analytical Report 2020

Point of Entry: 10298 Mill Street (East)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	33.3			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	2	BRL			
Barium		µg/L	25	BRL			
Beryllium		µg/L	2	BRL			
Cadmium		µg/L	2	BRL			
Calcium		mg/L	2	14.5			
Chromium		µg/L	5	BRL			
Cl ₂ , Total		mg/L	0.1	3.7			
Conductivity		umhos/cm	10	270.7			
Copper	1300	µg/L	25	BRL			
Hardness		mg/L	5	56.0			
Iron		µg/L	5	BRL			
Lead	15	µg/L	2	BRL			
Manganese		µg/L	25	BRL			
Nickel		µg/L	5	BRL			
NO ₂ +NO ₃	10	mg/L	0.2	0.8			
o-PO ₄		mg/L	0.05	1.4			
Selenium	50	µg/L	2	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	27.9			
Thallium		µg/L	2	BRL			
Total HAA	60	µg/L	1	4.0			
Total THM	80	µg/L	1	5.1			
Turbidity		NTU	0.1	0.3			
Zinc		µg/L	25	BRL			

MCL = Maximum Contamination Level

mg/L = milligrams per liter, parts per million

SU = Standard Units

C = Celcius

µg/L = micrograms per liter, parts per billion

NTU = Nephelometric Turbidity Units

umhos/cm = micromhos per centimeter

RL = Reporting Limit

BRL = Below Reporting Limit

Note: some of the data is averaged and based on multiple collections.

Report No. 200325122614



Certified Water Testing

VELAP ID: 460012

VA DW ID: 00240

EPA ID: VA00050

1851 Rippon Boulevard

Woodbridge, VA 22191

703-393-2071

Average Point of Entry Analytical Report 2020

Point of Entry: 14329 Glenkirk Road (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	36.7			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	2	BRL			
Barium		µg/L	25	BRL			
Beryllium		µg/L	2	BRL			
Cadmium		µg/L	2	BRL			
Calcium		mg/L	2	13.0			
Chromium		µg/L	5	BRL			
Cl ₂ , Total		mg/L	0.1	2.8			
Conductivity		umhos/cm	10	212.6			
Copper	1300	µg/L	25	BRL			
Hardness		mg/L	5	52.0			
Iron		µg/L	5	BRL			
Lead	15	µg/L	2	BRL			
Manganese		µg/L	4	BRL			
Nickel		µg/L	5	BRL			
NO ₂ +NO ₃	10	mg/L	0.2	0.4			
o-PO ₄		mg/L	0.05	0.9			
Selenium	50	µg/L	2	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	19.4			
Thallium		µg/L	2	BRL			
Total HAA	60	µg/L	1	14.0			
Total THM	80	µg/L	1	17.8			
Turbidity		NTU	0.1	0.8			
Zinc		µg/L	25	BRL			

MCL = Maximum Contamination Level

mg/L = milligrams per liter, parts per million

SU = Standard Units

C = Celcius

µg/L = micrograms per liter, parts per billion

NTU = Nephelometric Turbidity Units

umhos/cm = micromhos per centimeter

RL = Reporting Limit

BRL = Below Reporting Limit

Note: some of the data is averaged and based on multiple collections.

Report No. 200325122614



Certified Water Testing

VELAP ID: 460012

VA DW ID: 00240

EPA ID: VA00050

1851 Rippon Boulevard

Woodbridge, VA 22191

703-393-2071

Average Point of Entry Analytical Report 2020

Point of Entry: 8230 Patton Lane (West)

Test	MCL	Units	RL	Quarter 1	Quarter 2	Quarter 3	Quarter 4
Alkalinity		mg/L	20	70.0			
Aluminum		µg/L	25	BRL			
Antimony		µg/L	2	BRL			
Arsenic	10	µg/L	2	BRL			
Barium		µg/L	25	30.1			
Beryllium		µg/L	2	BRL			
Cadmium		µg/L	2	BRL			
Calcium		mg/L	2	32.6			
Chromium		µg/L	5	BRL			
Conductivity		umhos/cm	10	287.9			
Copper	1300	µg/L	25	BRL			
Hardness		mg/L	5	110.0			
Iron		µg/L	5	BRL			
Lead	15	µg/L	2	BRL			
Manganese		µg/L	25	BRL			
Nickel		µg/L	5	BRL			
NO2+NO3	10	mg/L	0.2	1.6			
o-PO4		mg/L	0.05	1.3			
Selenium	50	µg/L	2	BRL			
Silver		µg/L	5	BRL			
Sodium		mg/L	2	11.7			
Thallium		µg/L	2	BRL			
Total HAA	60	µg/L	1	2.0			
Total THM	80	µg/L	1	5.1			
Turbidity		NTU	0.1	0.4			
Zinc		µg/L	25	BRL			

MCL = Maximum Contamination Level

mg/L = milligrams per liter, parts per million

SU = Standard Units

C = Celcius

µg/L = micrograms per liter, parts per billion

NTU = Nephelometric Turbidity Units

umhos/cm = micromhos per centimeter

RL = Reporting Limit

BRL = Below Reporting Limit

Note: some of the data is averaged and based on multiple collections.

Report No. 200325122614