

June 2021 Operations Report

Water

- **Flow – Well 1b:** 8,387,700 gallons **Well 2:** 3,320,900 gallons **Total:** 11,707,900 gallons
- **Water Conservation:** The first couple weeks of being under stage 2 has seen numerous violations of water use. Operators are surveying the district in the mornings during rounds to spot residences that are water on the wrong days or time. There have been around 60 notices sent out to customers that include what Stage 2 entails and when they can water. Compliance has increased as people are being educated on the parameters, with operators noticing fewer violations as time passes.
- **Well 2 LMI:** Over the past month, operators have been experiencing issues with the chlorine dosing pump at Well 2 losing prime. After multiple attempts to fix the issue, operators were able to find a valve that will “bleed-off” any air trapped in the feed lines. This air was the cause of the pump losing prime. Since the installation of the device, operators have had no issues with pump losing prime.

Wastewater

- **Flow – WWTP 6:** 364,435 gallons **WWTP 7:** 733,338 gallons **Total:** 1,097,773 gallons
- **WWTP 7 Lift Station:** Last month, it was reported that operators had to replace a pump and experienced problems like those experienced at WWTP 6 last year. Greg Lyman from Farr West made a site visit to the lift station and discussed with operators the problems that happened during the last pump replacement. Greg took pictures and drew sketches of the lift station and will come up with a preliminary scope for the project. Operators will review the scope and work through the project with Farr West. This project is not an emergency like WWTP 6. The district can be deliberate with this project and not rush to get it done.

Misc., Future & Small Projects

- **Property Cleanup:** Operators continue to do cleanup on district properties. They have begun cutting weeds on the properties throughout the district. There are a couple large areas left, the meadow on Ponderosa and a district lot at the end of Ponderosa. Operators have coordinated with the Fire Department to be on standby while the large meadow on Ponderosa is mowed, this should be completed within the next couple weeks.
- **Madora Lake Rd. Transmission Lines:** Operators and Farr West met with representatives from USFS, Sierra Pacific Industries and road contractors to discuss the location of district water lines going to and from the water tanks, line depth, line protection during road repair & logging operations. Farr West has written a letter and

submitted it to the USFS detailing the depths of the lines and the expectations for protection of those lines. Due to the heat and Spotted Owl concerns, there will be no activity taking place until after October 1st.

- **Painting Projects:** Operators reenforced and painted the walkway entering the building on the north side. The railings were becoming unstable, so operators used 4x4s, dug holes and cemented the post to reenforce the walkway. Once that was complete, they painted the walkway and railing to match the trim of the building better than the red color that existed previously. All this was done prior to the PECAUX BBQ that took place July 3rd. Operators plan on painting WWTP 6 next.